



Declaration of Performance

Kingspan K-Stop® Coated Batt

1001.CPR.KStopCoatedBatt.001

Unique identification code of the product-type:
Intended use/es:

Kingspan K-Stop® Coated Batt
A mineral wool board coated on both faces used to
reinstate the fire resistance performance of wall
constructions with service penetrations.

Manufacturer:

Kingspan Technical Insulation Ltd,
Harvey Road,
Basildon,
SS13 1QJ

Notified Representative:

Kingspan Insulation NV – Visbeekstraat 24 – B-2300,
Turnhout (BE)

System/s of AVCP:

System 1

Harmonised technical specification:

EAD 350454-00-1104
EAD 350141-00-1106

ETA number:

ETA 23/0790 and ETA 23/1008

Technical Assessment Body:

UL International (Netherlands) B.V.

Notified body:

DBI Certification A/S No. 2531

Product type: Coated Batt		Intended use: Penetration seal and Linear joint & Gap seal
Assessment method	Essential characteristics	Product performance
BWR 2 Safety in case of fire		
EN 13501-1	Reaction to fire	D – s1, d0
EN 13501-2	Resistance to fire	ETA 23/0790 Annex A ETA 23/1008 Annex A
BWR 3 Hygiene, health and environment		
EN 1026	Air permeability	ETA 23/0790 Annex B ETA 23/1008 Annex B
EAD 350454-00-1104 / EAD 350141-00-1106, Annex C	Water permeability	NPD
Declaration of manufacturer & EN 16516	Release of dangerous substances	Declaration of manufacturer Use categories: IA1,S/W2
BWR 4 Safety in use		
EOTA TR 001:2003	Mechanical resistance and stability	Pass for 50mm batt or thicker
EOTA TR 001:2003	Resistance to impact/ movement	Pass
EOTA TR 001:2003	Adhesion	NPD
EAD 350454-00-1106, Clause 2.2.12 EAD 350454-00-1104, Clause 2.2.9	Durability	Y ₁
BWR 5 Protection against noise		
EN 10140-1,2,4,5 / EN ISO 717-1	Airborne sound insulation	29 (-1;-3) dB ¹ 29 (0;2) dB ² 52 (-4;-7) dB ³ 53 (-4;-7) dB ⁴



Declaration of Performance

BWR 6 Energy economy and heat retention		
EN 12664, EN 12667, EN 12939, EN ISO 8990, EN ISO 6946, EN ISO 14683, EN ISO 10211, EN ISO 10456	Thermal properties	NPD
EN ISO 12572, EN 12086, EN ISO 10456	Water vapour permeability	NPD
¹ Single 50 mm K-Stop® Coated Batt 2-S ² Single 60 mm K-Stop® Coated Batt 2-S ³ Double 50 or 60 mm K-Stop® Coated Batt 1-S or 2-S ⁴ Double 50 or 60 mm K-Stop® Coated Batt 1-S or 2-S with 50 mm cavity		

NPD = No performance determined

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Terry McGivern

Terry McGivern (Jun 16, 2026 11:05:44 GMT+1)

Terry McGivern
Managing Director
England, UK
Issue Number 001

To check that you have the latest version of this DoP please visit www.kingspanpassivefireprotection.com.

To access pre-existing product information or information relating to previously sold/ discontinued products please email literature@kingspaninsulation.co.uk.