



Declaration of Performance

Kingspan K-Stop® Pipe Collar

1001.CPR.KStopPipeCollar.001

Unique identification code of the product-type:
Intended use/es:

Manufacturer:

Notified Representative:

System/s of AVCP:

Harmonised technical specification:

ETA number:

Technical Assessment Body:

Notified body:

Kingspan K-Stop® Pipe Collar

A red coated steel shell with a graphite based reactive material which can be fitted around service penetrations.

Kingspan Technical Insulation Ltd,
Harvey Road,
Basildon,
SS13 1QJ

Kingspan Insulation NV – Visbeekstraat 24 – B-2300,
Turnhout (BE)

System 1

EAD 350454-00-1104

ETA 23/0792

UL International (Netherlands) B.V.

DBI Certification A/S No. 2531

Product type: Pipe Collar		Intended use: Penetration seal
Assessment method	Essential characteristics	Product performance
BWR 2 Safety in case of fire		
EN 13501-1	Reaction to fire	NPD
EN 13501-2	Resistance to fire	ETA 23/0792 Annex A
BWR 3 Hygiene, health and environment		
EN 1026	Air permeability	ETA 23/0792 Annex B
EAD 350454-00-1104, Annex C	Water permeability	NPD
Declaration of manufacturer & EN 16516	Release of dangerous substances	Use categories: IA1, S/W2 Declaration of manufacturer
BWR 4 Safety in use		
EOTA TR 001:2003	Mechanical resistance and stability	NPD
EOTA TR 001:2003	Resistance to impact/ movement	NPD
EOTA TR 001:2003	Adhesion	NPD
EAD 350454-00-1104, Clause 2.2.9	Durability	Z ₂
BWR 5 Protection against noise		
EN 10140-1,2,4,5 / EN ISO 717-1	Airborne sound insulation	R _w (C;C _{tr})= 58 (-1;-7)
BWR 6 Energy economy and heat retention		
EN 12664, EN 12667, EN 12939, EN ISO 8990, EN ISO 6946, EN ISO 14683, EN ISO 10211, EN ISO 10456	Thermal properties	NPD
EN ISO 12572, EN 12086, EN ISO 10456	Water vapour permeability	NPD

NPD = No performance determined

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.



Declaration of Performance

Signed for and on behalf of the manufacturer by:

Terry McGivern

[Terry McGivern \(Jun 16, 2026 11:05:44 GMT+1\)](#)

Terry McGivern
Managing Director
England, UK
Issue Number 001

To check that you have the latest version of this DoP please visit www.kingspanpassivefireprotection.co.uk

To access pre-existing product information or information relating to previously sold/ discontinued products please email literature@kingspaninsulation.co.uk.