

UK Declaration of Performance

Kingspan K-Stop® Pipe Collar

1001.CPR.KStopPipeCollar_UK.001

Unique identification code of the product-type:

Intended use/es:

Manufacturer:

System/s of AVCP:

Harmonised technical specification:

UKTA number:

Technical Assessment Body:

Notified body:

Kingspan K-Stop® Pipe Collar

A red coated steel shell with a graphite based reactive material which can be fitted around service penetrations.

Kingspan Technical Insulation Limited,
Harvey Rd,
Basildon,
SS13 1QJ

System 1

EAD 350454-00-1104

0843-UKTA-23/0017

UL International (UK) Ltd

UL International (UK) Ltd 0843

Product type: Pipe Collar		Intended use: Penetration Seal
Assessment Method	Essential Characteristics	Product Performance
BWR 2 Safety in case of fire		
EN 13501-1	Reaction to fire	NPD
EN 13501-2	Resistance to fire	0843-UKTA-23/0017 Annex A
BWR 3 Hygiene, health and environment		
EN 1026	Air permeability	0843-UKTA-23/0017 Annex B
EAD 350454-00-1104, Annex C	Water permeability	NPD
Declaration of manufacturer & EN 16516	Release of dangerous substances	Use categories: IA1, S/W2 Declaration of manufacturer
BWR 4 Safety in use		
EOTA TR 001:2003	Mechanical resistance and stability	NPD
EOTA TR 001:2003	Resistance to impact/movement	NPD
EOTA TR 001:2003	Adhesion	NPD
EAD 350454-00-1104, Clause 2.2.9	Durability and serviceability	Z ₂
BWR 5 Protection against noise		
EN 10140-1,2,4,5 / EN IS 717-1	Airborne sound insulation	R _w (C;Ctr): 58 (-1;-7)
BWR 6 Energy economy and heat retention		
EN 12664, EN 12667, EN 12939, EN ISO 8990, EN ISO 6946, EN ISO 14683, EN ISO 10211, EN ISO 10456	Thermal properties	NPD
EN ISO 12572, EN 12086, EN ISO 10456	Water vapour permeability	NPD

NPD = No performance determined



UK Declaration of Performance

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Note: Conformity assessment activities undertaken by EU-recognised Conformity Assessment Bodies before 31 December 2022 are allowed to declare existing product types as compliant with UKCA requirements.

This declaration of performance is issued, in accordance with EU Regulation 305/2011, as retained in UK law, and as amended by SI no. 465/2019 (the Construction Products (Amendment etc.) (EU Exit) Regulations 2019) and SI no. 1359/2020 (the Construction Products (Amendment etc.) (EU Exit) Regulations 2020).

Signed for and on behalf of the manufacturer by:

Terry McGivern
Terry McGivern (Jun 16, 2026 07:24:52 GMT+1).....

Terry McGivern
Managing Director
Basildon, England, UK
Issue Number 001

To check that you have the latest version of this DoP please visit www.kingspanpassivefireprotection.co.uk

To access pre-existing product information or information relating to previously sold/ discontinued products please email literature@kingspaninsulation.co.uk.