

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Certificate No.
0843-CPR-1302

Issue date
16-08-2023

Issue No.
3

Re-Issue date
10-07-2025



4705

This is to certify that UL International (UK) Ltd. did undertake the relevant AVCP procedures for the equipment identified below which was found to be in compliance with the Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, subject to any conditions attached hereto.

Manufacturer:
Kingspan Technical Insulation Ltd

Address:
Harvey Rd, Basildon, SS13 1QJ

Product:
Kingspan K-Stop® Pressure Exerting Graphite Mastic

Places of production:
A/003

Harmonized requirements
EAD 350454-00-1104; September 2017

Scope of Certificate
0843-UKTA-23/0013 issued on 09/07/2025

On behalf of the Head of Approved Body:

A blue ink signature of Chris Johnson.

Chris Johnson
Issued by UL International (UK) Ltd, Approved Body 0843.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in UKTA-23/0013 of the above referenced standards, under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate will remain valid as long as neither the EAD, UKTA-23/0013, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the UK Approved body.



Solutions

Form-ULID-006104 V8.0

Detailed information sheet:

Product Reference:	Kingspan K-Stop® Pressure Exerting Graphite Mastic
Type:	Firestop – Sealant and pipe closure device used as a penetration seal
Description:	<p>Kingspan K-Stop® Pressure Exerting Graphite Mastic is a sealant and pipe closure device used to form penetration seals where insulated metallic pipes, combustible pipes, combustible cable conduits and cables penetrate walls and floors.</p> <p>The Kingspan K-Stop® Pressure Exerting Graphite Mastic is supplied in liquid form contained within 310 & 380 ml cartridges and 600 ml foil packs. The sealant is gunned into the aperture in the separating element and around the service or services, to a specified depth utilising mineral fibre insulation backing material.</p>
Key Performance parameters:	See 0843-UKTA-23/0013
Identification and intended use	See Product Label

Limitations on the acceptance or use of the product(s):

Installation instructions	To be used in accordance with the supplier’s installation instructions, technical datasheet and UKTA.
Limitations	See Technical Data Sheet and the UKTA
UL Report:	4791836379

Terms and Conditions:

1. This certificate remains the property of UL International (UK) Ltd, herein “UL UK”, and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and UKCA CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL UK.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL UK.
5. This certificate is only valid for placing goods on the market of United Kingdom excluding Northern Ireland.

END OF CERTIFICATE

