

UK Declaration of Performance

Kingspan K-Stop® Putty Pad

1001.CPR.KStopPuttyPad_UK.001

Unique identification code of the product-type:
Intended use/es:

Kingspan K-Stop® Putty Pad
A fire rated sealant supplied as a non-setting putty in the shape of an intumescent sheet. It can be hand worked into electrical socket boxes.

Manufacturer:

Kingspan Technical Insulation Limited,
Harvey Rd,
Basildon,
SS13 1QJ
System 1

System/s of AVCP:

EAD 350454-00-1104

Harmonised technical specification:

0843-UKTA-23/0018

UKTA number:

Technical Assessment Body:

UL International (UK) Ltd

Notified body:

UL International (UK) Ltd 0843

Product type: Intumescent sheet		Intended use: Penetration seal
Assessment Method	Essential Characteristics	Product Performance
BWR 2 Safety in case of fire		
EN 13501-1	Reaction to fire	NPD
EN 13501-2	Resistance to fire	0843-UKTA-23/0018 Annex A
BWR 3 Hygiene, health and environment		
EN 1026	Air permeability	0843-UKTA-23/0018 Annex B
EAD 230454-00-1104, Annex C	Water permeability	NPD
Declaration of manufacturer & EN 16516	Content, emission and/or release of dangerous substances	Use categories: IA1 Declaration of manufacturer
BWR 4 Safety in use		
EOTA TR 001:2003	Mechanical resistance and stability	NPD
EOTA TR 001:2003	Resistance to impact/movement	
EOTA TR 001:2003	Adhesion	
EAD 350454-00-1104, Clause 2.2.9	Durability	Z ₂
BWR 5 Protection against noise		
EN 10140-1,2,4,5 / EN ISO 717-1	Airborne sound insulation	R _w (C;C _{tr})= 67 (-2;-7) dB*
BWR 6 Energy economy and heat retention		
EN 12664, EN 12667, EN 12939, EN ISO 8990, EN ISO 6946, EN ISO 14683, EN ISO 10211, EN ISO 10456	Thermal properties	NPD
EN ISO 12572, EN 12086, EN ISO 10456	Water vapour permeability	NPD

*Applicable only for K-Stop Putty Pads in socket boxes

NPD = No performance determined



UK Declaration of Performance

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Note: Conformity assessment activities undertaken by EU-recognised Conformity Assessment Bodies before 31 December 2022 are allowed to declare existing product types as compliant with UKCA requirements.

This declaration of performance is issued, in accordance with EU Regulation 305/2011, as retained in UK law, and as amended by SI no. 465/2019 (the Construction Products (Amendment etc.) (EU Exit) Regulations 2019) and SI no. 1359/2020 (the Construction Products (Amendment etc.) (EU Exit) Regulations 2020).

Signed for and on behalf of the manufacturer by:

Terry McGivern
Terry McGivern (Jun 16, 2026 07:24:52 GMT+1)

Terry McGivern
Managing Director
Basildon, England, UK
Issue Number 001

To check that you have the latest version of this DoP please visit www.kingspanpassivefireprotection.co.uk

To access pre-existing product information or information relating to previously sold/ discontinued products please email literature@kingspaninsulation.co.uk.